



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 8/11/09

Code 50.10.1.5-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – *Dashed line through material to be deleted, underline material to be added*)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title Figure R602.6.1, Top plate framing to accommodate piping		Page 1 of 1
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Change the text on Figure R602.6.1 to read as follows: ...fastened across and to the plate at each side of the notch with 8-16d <u>8-10d</u> nails at each side</p>		
REASON		
<p>To align with text.</p>		
Fiscal impact: no increase to the cost of construction.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		